MY WATER STAINS FIXTURES BLACK							
LIKELY	HEALTH	OTHER CLUES &	CONFIRM	POSSIBLE	LICENSE REQUIRED	STATE	MORE
PROBLEM	CONCERN?	CONSIDERATIONS	IT	FIXES	FOR FIX?	FUNDS?	INFO
Manganese	Possibly, if	Do you have black	Test your	Install a Dept.	Yes, treatment devices	No	UWSP Well
or	levels are	specks in your	water for	of Safety and	must be installed by		<u>Water</u>
Manganese	very high.	water? When you	manganese	Professional	<u>licensed plumbers</u> ; or in		<u>Quality</u>
and Iron	Manganese	rub the specks	and iron.	Services	some cases may be		<u>Viewer</u>
See	is a	between your fingers,	Contact a	<u>approved</u>	installed by the		
<u>Iron in</u>	necessary	does it leave a black	<u>laboratory</u>	<u>water</u>	owner/occupant of a		<u>United</u>
<u>Drinking</u>	mineral for	powder? Do you	certified by	<u>treatment</u>	single family private		<u>States</u>
<u>Water</u>	good health	have dark stains on	DNR to test	device.	residence. See		<u>Geological</u>
brochure.	and there is	plumbing fixtures?	<u>for</u>	Devices are	plumbing license laws.		<u>Survey</u>
	not a primary		<u>manganese</u>	listed under			
	drinking		and iron.	contaminants	Be sure the treatment		<u>National</u>
	water			they will	device chosen is capable		<u>Ground</u>
	standard for			remove.	of removing the amount		<u>Water</u>
	manganese.				of manganese and iron		<u>Association</u>
	There is				you have in your water.		
	however, a						<u>Water</u>
	<u>nuisance</u>						<u>Systems</u>
	<u>standard</u> for						<u>Council</u>
	manganese.						
	Also, EPA						<u>National</u>
	has issued a						Sanitation
	<u>health</u>						<u>Foundation</u>
	advisory for						0
	<u>manganese</u>						Center for
	See the						<u>Watershed</u>
	Department						Science and
	of Health						Education,
	Services						<u>UW-Stevens</u>
	Fact Sheet						<u>Point</u>
	<u>on</u>						
	Manganese.						